



Long Term Development Statement for Scottish Hydro Electric Power Distribution plc's Electricity Distribution System



NOVEMBER 2022

SCOTTISH HYDRO ELECTRIC POWER DISTRIBUTION plc

LONG TERM DEVELOPMENT STATEMENT

FOREWORD

Scottish Hydro Electric Power Distribution plc (SHEPD) is pleased to present this Long Term Development Statement (LTDS) for its electricity distribution network. It is produced by SHEPD in accordance with its Electricity Distribution Standard Licence Condition (SLC) 25. The statement covers the period 2022/23 to 2026/27.

The main purpose of the LTDS is to assist existing and prospective users of the electricity distribution network in assessing opportunities available for making new connections, or for additional use of the SHEPD distribution system.

The assets referred to in this document are in the ownership of Scottish Hydro Electric Power Distribution plc which delivers electricity to over 785,000 customers in Scotland.

Although all reasonable efforts have been made to ensure the accuracy of data, SHEPD does not accept any liability for the accuracy of the information contained herein and in particular neither SHEPD, nor its directors or employees, shall be under any liability for any errors.

This document may not be reproduced, in whole or part, for any purpose, without the written consent of Scottish Hydro Electric Power Distribution plc.

CONTENTS

INTRODUCTORY INFORMATION (PART 1)

1. Purpose of Statement
2. Contents of Statement
3. Contact Details
4. Other Information Sources

SUMMARY INFORMATION (PART 2)

1. Guiding Principles for Planning the Distribution System
2. Standards
 - 2.1 Licence Conditions
 - 2.2 Distribution Code
 - 2.3 Electricity Safety, Quality and Continuity Regulations
 - 2.4 Environmental Standards
 - 2.5 Company Internal Standards
 - 2.5.1 General
 - 2.5.2 Capacity Planning
 - 2.5.3 System Voltage Control
3. Design Policies
 - 3.1 General
 - 3.2 33 kV System Design
 - 3.3 Supplies from 33/11 kV Substations
 - 3.4 11 kV Network Configuration
 - 3.5 Low Voltage Network Configuration
4. Network Characteristics
 - 4.1 Standard Plant and Equipment sizes
 - 4.1.1 33 kV System
 - 4.1.2 11 kV System
 - 4.1.3 Telecontrol
 - 4.1.4 Batteries
 - 4.2 Power Quality
 - 4.2.1 Harmonics
 - 4.2.2 Voltage Fluctuations
 - 4.2.3 Unbalance
 - 4.2.4 Investigations
 - 4.3 Method of Earthing
 - 4.3.1 Primary substations
 - 4.3.2 Distribution Substations
 - 4.3.3 Low Voltage System
 - 4.4 Protection Systems
 - 4.4.1 General
 - 4.4.2 LV Feeders
 - 4.4.3 11 kV/LV Transformers (Ground Mounted)
 - 4.4.4 11 kV/LV Transformers (Pole Mounted)
 - 4.4.5 11 kV Feeders

- 4.4.6 33/11 kV Transformers
- 4.4.7 33 kV Feeders and Transformer Feeders
- 4.5 Network Automation
- 4.6 Auto Reclosers
- 4.7 Operating Voltages
 - 4.7.1 General
 - 4.7.2 Voltage Control of 11 kV and LV system
 - 4.7.3 Voltage Control of 33 kV System
- 4.8 Generation Connection Policy
- 4.9 Load Management Areas
- 4.10 Network Constraints and Opportunities
- 4.11 Transmission Constraints

5. Geographic and Schematic Plans

6. Other Sources of Network Information

7. Detailed Information

- 7.1 Overview of the System
- 7.2 Network data
 - 7.2.1 Circuit Data
 - 7.2.2 Transformer Data
 - 7.2.3 Demand Data
 - 7.2.4 Fault Level Data
 - 7.2.5 Generation Data
 - 7.2.6 Interest in a connection
- 7.3 Other Information

8. Network Development Proposals

9. Further Information

- 9.1 Distribution Code
- 9.2 Electricity Ten Year Statement
- 9.3 Engineering Recommendations

APPENDIX 1 NETWORK INFORMATION PRICE LIST

Network Data

Geographic Mapping Information

APPENDIX 2 TYPICAL 33/11 KV SUBSTATION LOAD PROFILES

APPENDIX 3 NETWORK DEVELOPMENT PROPOSALS

INTRODUCTORY INFORMATION (PART 1)

1. Purpose of Statement

This Long Term Development Statement (LTDS) is prepared in accordance with Standard Licence Condition 25.

The purpose of this statement is to:

- Provide sufficient information which will assist existing and prospective new users who contemplate entering into distribution arrangements with the licensee, to identify and evaluate opportunities.
- Ensure the general availability of such information in the public domain.
- Inform users of distribution network development proposals.
- Provide users of the correct point of contact for specific enquires.

Users of the distribution system should also be aware that the main document which governs development and operation of the distribution system is the Distribution Code. This code covers all material technical aspects relating to connections to and the operation and use of the distribution systems of the Licensee.

2. Contents of Statement

This LTDS is in two parts.

- Part 1 gives an overview of document content and provides relevant contact details and sources of information.
- Part 2 contains detailed information of the system.

The statement contains a range of information associated with our 33 kV distribution system including the 11 kV busbar of 33/11 kV primary substations.

Information relating to 11 kV and LV systems may be available on request depending on area. A price list for the provision of this data is included in Appendix 1.

Part 2 of the statement gives:

- Detailed information on the guiding principles for planning the distribution system, company internal standards, design policies and network characteristics.
- Schematic and geographical plans showing the 33 kV system including location of 132/33 kV and 33/11 kV substations.
- Details of embedded generation.
- Planned network development proposals for which financial approvals have been given in Appendix 3. They provide a summary of the work to be carried out, timescale and area of the network impacted by each proposal. These exclude like for like replacement (as this does not change system capability) and system developments for new or existing users.

- Detailed information relating to:
 - Circuit Data, Table 1
 - Transformer Data, Table 2
 - Demand Data*, Table 3
 - Fault Level Data*, Table 4
 - Generation Data, Table 5
 - Connection Interest Table 6
 - Schematic Diagrams of the Distribution Network Single Line Diagrams

* Demand forecast methodology is formulated around a combination of important contributing factors impacting demand. Historic growth rates for each primary substation are calculated before being banded into four growth trends of Zero, Low, Medium, or High.

Individual future growth rates are based on the calculated historic trend and key drivers including committed connections, geographic economic factors derived from local authority development plans and demand forecast from large users with knowledge of major changes in connected load.

The key assumptions included in the demand forecast are as follows:

- Exponential growth is assumed and calculated using historic maximum demand readings over the past five years.
- Consistent running arrangement and system configurations are considered. Recorded substation peak demands are normalised to account for abnormal running arrangements or equipment faults to ensure the forecast is consistent to previous years running arrangement.
- Power export from distributed generators (DG) is removed, where possible, from recorded figures to give a true representation of underlying substation demand.
- Individual demand forecast submissions from large consumers are factored into forecasts
- Committed new loads and new connections are assumed to materialise in the manner predicted i.e., user timing and usage is assumed to occur as advised/requested by customer.
- Future Zero growth rates are assumed to have a forecast trend of 100% i.e., neither increasing nor decreasing.

* SHEPD will undertake further assessments to determine whether intervention is required where the calculated planning fault levels, identified in Table 4, exceed 95% of the circuit breaker fault level rating. The additional assessments undertaken by SHEPD include, but are not limited to, site specific protection settings analysis and circuit breaker trip testing.

If further assessments confirm that intervention is required SHEPD will determine the most economic, efficient and cost-effective solution to reduce the overall fault level. Possible mitigation works include, but are not limited to, opening the bus-section circuit breaker, reconfiguring the network, installing fast response automation, and extending circuit breaker trip times.

Details of the 132 kV system (regarded as transmission voltage in Scotland) are included in the Electricity Ten Year Statement, which is available on National Grid's Electricity System Operator website. <https://www.nationalgrideso.com/>

3. Contact Details

Further copies of this LTDS can be requested by sending an email to:

system.planning.north@sse.com

or by making a request through the Scottish and Southern Electricity Networks website:

<https://www.ssen.co.uk/our-services/tools-and-maps/long-term-development-statements-ltds/>

For information or feedback relating to LTDS:

System Planning North
Scottish Hydro Electric Power Distribution plc
Inveralmond House
200 Dunkeld Road
Perth
PH1 3AQ
E-mail: system.planning.north@sse.com

Enquiries relating to new load connections or changes to existing load connections should be addressed to:

Connections and Engineering
Scottish and Southern Electricity Networks
Walton Park
Walton Road
Cosham
PO6 1UJ
E-mail: connections@sse.com
Tel: 0800 0483516

Enquiries relating to connection of generators should be addressed to:

Major Connections Contracts (MCC)
Scottish and Southern Electricity Networks
Perth Training Centre
Ruthvenfield Way
Inveralmond Industrial Estate
Perth
PH1 3AF
E-mail: mcc@sse.com
Tel: 0345 0724319

Enquiries relating to connection of generators should review the options on the Scottish and Southern Electricity Networks website:

<http://www.ssen.co.uk/GenerationConnectionsHome/>

Enquiries relating to the provision of copies of the "Use of system charging statement" should be addressed to:

Distribution Pricing Team
Scottish Hydro Electric Power Distribution plc
Inveralmond House
200 Dunkeld Road
Perth
PH1 3AQ
Email: DistributionPricingTeam@sse.com

Enquiries relating to the provision of copies of the "Statement of methodology and charges for connection" should be addressed to:

Connections Policy Team
Scottish Hydro Electric Power Distribution plc
Inveralmond House
200 Dunkeld Road
Perth
PH1 3AQ
Email: connections.policy@sse.com

The Connection and Use of System charging statements can be viewed on our website. Our connection charging statements are revised from time to time and our Use of System charging statements are revised at least annually. Revised Use of System charges normally take effect from 1 April of each year. The latest documents can be viewed via the link below:

<http://www.ssen.co.uk/Library/ChargingStatements/SHEPD/>

4. Other Information Sources

Distributed Generation Connection Guide

The ENA produces connection guides to help users as an owner or developer of distributed generation to connect distributed generation to the UK's electricity distribution networks.

The guides can be viewed by following the link below:

<https://www.energynetworks.org/operating-the-networks/connecting-to-the-networks>

Guaranteed Standards

In accordance with the Electricity (Standards of Performance) Regulations 2015, DNOs are obliged to meet guaranteed standards of performance set by Ofgem, the industry regulator.

These guaranteed standards are laid out in three documents which can be viewed by following the below links:

The Guaranteed Standards:

- The Electricity (Connection Standards of Performance) Regulations 2015

http://www.legislation.gov.uk/uksi/2015/698/pdfs/uksi_20150698_en.pdf

Part 2 – Services and Standards for Metered Connections

Part 3 – Services and Standards for Unmetered Connections

- The Electricity (Standards of Performance) Regulations 2015

http://www.legislation.gov.uk/uksi/2015/699/pdfs/uksi_20150699_en.pdf

- The Electricity and Gas (Standards of Performance) (Suppliers) Regulations 2015

http://www.legislation.gov.uk/uksi/2015/1544/pdfs/uksi_20151544_en.pdf

Process to Request Additional Network Data

Enquiries relating to the provision of additional network data to that contained in the LTDS should be sent to:

system.planning.north@sse.com